

S-VENT[®]

SUBMITTAL SHEET



Anemostat[®]


A MESTEK COMPANY

P.O. BOX 4938 • 1220 WATSONCENTER ROAD • CARSON, CA 90745-4206
 (310) 835-7500 • FAX (310) 835-0448
 e-mail: airsec@anemostat.com • website: www.anemostat.com


SV49-__-PC

SPECIFY TYPE
MAXIMUM SECURITY GRILLE
 1/2" HORIZONTAL OPENING
 with
 ANCHOR STUDS
 FOR PRECAST CONCRETE


TOP SECTION



FRONT SECTION



SIDE SECTION



IMPORTANT: It is the specifier's responsibility to properly configure the HVAC system to meet the appropriate level of comfort, safety, security and detention

PRODUCT FEATURES

Face Flange

16 GA (standard)

Material Type

Cold Rolled Steel (standard)

Horizontal Louvers/Vertical Mullions

16 GA with 3 1/4" Neck Depth (std)

Finish

- Beige Powder Coat-5 to 7 mil (std)
- White Powder Coat-5 to 7 mil (opt)
- Other Powder Coat Colors _____

Sleeve (standard)

12 GA - specify length _____

Opposed Blade Damper (optional)
(shipped loose)

Rear Operated

Anchoring Studs (standard)

Nelson Type - specify stud size _____

MUST SPECIFY TYPE (BASED ON ROUGH OPENING SIZE) AS PART OF MODEL NUMBER WHEN PLACING ORDER

ROUGH OPENING SIZES (WIDTH X HEIGHT)

| Dimensions in Inches | | WIDTH | | | | | | | | |
|----------------------|----|-------|----|----|----|----|----|----|----|----|
| | | 7 | 9 | 11 | 13 | 15 | 17 | 19 | 21 | 23 |
| HEIGHT | 6 | A1 | B1 | C1 | D1 | E1 | F1 | G1 | H1 | J1 |
| | 8 | A2 | B2 | C2 | D2 | E2 | F2 | G2 | H2 | J2 |
| | 10 | A3 | B3 | C3 | D3 | E3 | F3 | G3 | H3 | J3 |
| | 12 | A4 | B4 | C4 | D4 | E4 | F4 | G4 | H4 | J4 |
| | 14 | A5 | B5 | C5 | D5 | E5 | F5 | G5 | H5 | J5 |
| | 16 | A6 | B6 | C6 | D6 | E6 | F6 | G6 | H6 | J6 |
| | 18 | A7 | B7 | C7 | D7 | E7 | F7 | G7 | H7 | J7 |
| | 20 | A8 | B8 | C8 | D8 | E8 | F8 | G8 | H8 | J8 |
| | 22 | A9 | B9 | C9 | D9 | E9 | F9 | G9 | H9 | J9 |

| QTY | TYPE | ROUGH OPENING W" X H" | WALL DEPTH |
|-----|------|-----------------------|------------|
| 27 | C4 | 11 X 12 | 6" |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

SUBMITTAL APPROVAL

| | | | |
|------------------------------|------|---------------------|------|
| Job Name and Location | | | |
| Engineer | Date | Factory | Date |
| Mfr. Rep. | Date | Submitted By | Date |

AUGUST 2008
 NEW CONSTRUCTION
 S-VENT SECURITY PRODUCTS PAGE 12